



C E R T I F I C A T E

Certificate No. 09-PPV-00042/01-W01-TIC

WE HEREBY CERTIFY THAT THE PHOTOVOLTAIC MODULES WITH THE MODEL

MBPV CAAP*

**And with Types extended for similarity*
- See Annex -**

MANUFACTURING & LICENSE HOLDER

MOSERBAER PHOTOVOLTAIC LIMITED

66-B, Udyog Vihar, Greater Noida 201306, (U.P) - India

IS IN COMPLIANCE WITH THE REQUIREMENTS OF

IEC 61215 : 2005

Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval

&

EN 61730-1 / EN 61730-2 : 2007

Photovoltaic (PV) module safety qualification

To be used in plants at a total voltage up to : 1000 Vdc

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY

EUROTEST LABORATORI

(EA ACCREDITED LABORATORY N. 0192)

REPORT No. TIC-PVC01CdO08C356001

&

THE FACTORY INSPECTION ON THE DATE 24th January 2009 WITH

REPORT No. RFI-0109-PPV-TIC-00042/01

Expiring date 29.01.2012

(Providing that the testing basis continues unchanged)

Notes: (*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type MBPV CAAP. Further details on certified models are reported on the attachment. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. CEI-EN 60904-1 "Measurement of PV module IV characteristics - CEI-EN 61345-1 "Ultraviolet test for PV modules" - Mechanical load test performed at 5400 Pa The certification is performed on tested model as complete certification This certificate is for type approval and based on voluntarily product test with Factory Inspection.** The Manufacturing Inspection was conducted by a TÜV INTERCERT appointed inspector on the base of agreement with the certification body TÜV INTERCERT.

